

Date Prepared 05/2001  
Prepared By Carla McGreevy  
Revised 5/3/05 P Watt

**BMP# Technical Services #3**

**TITLE:** HAZARDOUS WASTE AREA SIGNS

**Regulatory Citation:** 6 NYCRR Part 201-3.2(13)

**Applicability:** Hazardous Waste Storage Area – Chemical Vault

**Purpose:** Placarding of Hazardous Waste Storage Area.

**Person or**

**Department Responsible:** Technical Services

**Schedule:** As needed

**Procedures:** The door entering the Chemical Vault will be placarded with the following signs:

“Hazardous Waste”  
“Authorized Personnel Only”  
“Flammable”  
“No Smoking”

The following information must be posted at the emergency phone (see attached):

- Name and telephone number of the emergency coordinator (HVCC Public Safety) and the emergency contact person
- the phone number of the local fire department
- the location of: fire extinguisher, spill control material, fire alarm pull station.

Once posted the signs should be inspected and maintained.

**Record keeping:** Not Applicable.

**Record Location:** Not Applicable.

**Contacts:** Director of Tech Services (629-7477)  
Director of Environmental Health and Safety (629-7163)

HVCC-BMP-TECHS#3-HWsigns

# **IN CASE OF FIRE, SPILL OR RELEASE**



**CALL 911 FROM A CAMPUS PHONE  
TO REACH THE CAMPUS PUBLIC  
SAFETY OFFICE  
(629-7210 FROM CELL PHONE)**

## **OTHER EMERGENCY CONTACT INFORMATION:**

**HVCC EMERGENCY COORDINATOR IS STEVE COWAN  
FIRE DEPARTMENT: 911 OR 270-4471**

## **THIS LOCATION IS:**

**HVCC FITZGIBBONS BUILDING CHEMICAL VAULT  
80 VANDENBURGH AVE, TROY, NY**

## **LOCATION OF EMERGENCY EQUIPMENT:**

<b>FIRE ALARM PULL STATION</b>	<b>OUTSIDE CHEMICAL VAULT</b>
<b>FIRE EXTINGUISHER</b>	<b>OUTSIDE CHEMICAL VAULT</b>
<b>SPILL CONTROL MATERIAL</b>	<b>DRUM INSIDE VAULT AND FITZ ROOM 335</b>

